

DO NOT SCALE

IF IN DOUBT, ASK!

REVISIONS

REV.	DESCRIPTION	DATE	DRAWN
1	CC	04/08/2014	

NOTES:

1. WEIGHT TBC
2. UNIT SUPPLIED WITH 4 NO. FIXING BRACKETS
E-STACK CAN BE HUNG FROM 4 NO. M10 STEEL THREADED STUDDING
3. FINISH - GALV. (RAL AT ADDITIONAL COST)
4. GRILLES NOT SHOWN. GRILLES SUPPLIED AT ADDITIONAL COST
5. IF UNIT IS POSITIONED LESS THAN 2.7M ABOVE FINISH FLOOR LEVEL, FINGER GUARD GRILLES MUST BE USED
6. ACCESS TO CONTROL PANEL MUST BE PROVIDED

TOLERANCES EXCEPT WHERE OTHERWISE STATED

X	±	0.5MM
X.XX	±	0.05MM
ANGLES	±	0.5°

SURFACE TEXTURE TO BE 1.6 UMRA OR BETTER

DE-BURR ALL SHARP EDGES AND HOLES
ITEM MUST BE FREE FROM SCRATCHES, DENTS AND OTHER BLEMISHES.

DIMENSIONS IN MILLIMETRES



15 STURTON STREET, CAMBRIDGE, CB1 2SN
T: 01223 450060 F: 01223 450061
WWW.BREATHINGBUILDINGS.COM

TITLE:

E-STACK: S1200L VERSION 1

DRAWING NO:

1341_9002_01

MATERIAL: MILD STEEL

FINISH: GALV. OR POWDER COATED

REV DRAWN DATE CHK'D DATE

1	CC	04/08/2014		
---	----	------------	--	--

SCALE 1:22 A3 SHEET 1 OF 1

PLAN VIEW

