



DO NOT SCALE

IF IN DOUBT, ASK!

REVISIONS			
REV.	DESCRIPTION	DATE	DRAWN

- NOTES:
1. THE SIZING AND LOAD BEARING SUPPORTS MUST BE SIGNED OFF BY THE STRUCTURAL ENGINEER FOR THE PROJECT
 2. SITE SPECIFIC DIMENSIONS MUST BE TAKEN BY THE INSTALLER (I.E. NOT TO SCALE)
 3. IF UNDERSIDE OF UNIT IS <2.7M ABOVE FINISHED FLOOR LEVEL, THEN FINGER GUARD GRILLES MUST BE USED
 4. EGG CRATE GRILLES NOT SHOWN.

MATERIAL:
N/A

FINISH
N/A

MASS WITHOUT PACKAGING
N/A

TOLERANCES EXCEPT WHERE OTHERWISE STATED

X	±	0.5MM
X.XX	±	0.05MM
ANGLES	±	0.5°

SURFACE TEXTURE TO BE 1.6 UMRA OR BETTER

DE-BURR ALL SHARP EDGES AND HOLES
ITEM MUST BE FREE FROM SCRATCHES, DENTS AND OTHER BLEMISHES.

DIMENSIONS IN MILLIMETRES



15 STURTON STREET, CAMBRIDGE, CB1 2SN
T: 01223 450060 F: 01223 450061
www.breathingbuildings.com/products

TITLE:
F500E INSTALLATION GA

DRAWING NO:
1347_9003

REV	DRAWN	DATE	CHK'D	DATE
	CC	18/09/2015		

SCALE 1:22 A3 SHEET 1 OF 1



BREATHING BUILDINGS CONTINUOUSLY WORK TO IMPROVE OUR PRODUCTS. TO ENSURE UP TO DATE DRAWINGS, PLEASE CONTACT BREATHING BUILDINGS.