


Natural ventilation and low energy building design




shaun.fitzgerald@breathingbuildings.com

T 01223 450060

F 01223 450061




Energy Use In Buildings



Mechanical Ventilation Scheme

Significant HVAC equipment


Energy consumption - heating and cooling run simultaneously



Mechanical Ventilation Scheme

1st Floor Sunbury A, Week 16/11 through 21/11

Starts at 0600 Sat 16/11, finish 1050 on Thur 21/11



#1 near the end is mauve




#2 mid-way between 1 and 4 is green

#3 Stand near window, ¼ way along the building is red



#4 stand near the middle and away from the window is blue

#5 near the middle, but at the window is black


Displacement



Displacement



Simple Spaces




HOUGHTON HALL



A yellow sun icon with a circular center and eight triangular rays, positioned at the top of the page.










Complex Spaces



Which way does the air flow?



Complex Spaces – Houghton Hall



Water-bath Modelling




CFD Modelling

Multiple modes can be obtained with numerical modelling ... but


- You need to know what you are looking for!
- Time consuming!

Uniform initial conditions (20°C)



Air enters through 1st floor vents
→ cool interior


1st floor initially hotter than ground



Air exits through 1st floor vents
→ Hot 1st floor

Temperature Measurements

1st floor




- North side of the atrium
- East end of the atrium
- South side of the atrium
- West end of the atrium (dark blue line, very small peak)
- Within main floor

Atrium peak temperatures follow exposure to sun

Region near/within atrium hotter than desk area under exposed concrete → benefit of thermal mass

Temperature Measurements

3-21 July Average temperatures




Main floor
temperatures less
than outside and
buffered by
thermal mass...

but still rather
warm mid-July

Temperature Measurements


23July-14Aug average temperatures



Warm inside
again in early
August


Temperature Measurements

15Aug-10Sept Average temperatures




Cooler after
mid-August

Can we improve performance?




Time Lags




Range of time lag for building to reach max or min temp

August-Sep 2003





Buffer for max temp 1-3 hours

Maximising Effectiveness of Thermal Mass





Air Flow Results





Measurements show fresh air supply well in excess of minimum required

Night Time Operation




Upper part of atrium (2nd floor)

outside


Second floor

Opportunity for Improvement

July outside air temperature.




August outside temperature.



1. Opportunity to use cool air from outside during night **even more effectively** to reduce building temperature
2. Reduce window openings during summer day to **maximise benefit of thermal mass**

Contact Theatre, after renovation






Evening/
Morning
Warmer
inside
than
outside


Stack 3 inflow?

Stack 2 also inflow later?


Stack 1





Stack 2




Stack 3



Stack 4




Stack 3 inflow → balance of base and stack areas




Mid-points of stacks 1 + 4 cooler than stacks 2 + 3



Counterflow in stacks 1 + 4




Stack 2




Temperature




Stack 4






Mixing ventilation in practice when warmer inside and
stack area >> base vent area

Conventional Natural Ventilation




Winter – Upwards displacement ventilation

Recommended Winter Strategy




Winter – Mixing ventilation

Recommended Summer Strategy



Summer – Upwards displacement ventilation

Night Cooling



QAC, Birmingham



East Malling School, Kent



Pilgrim School, Kent




Control Interface


**Exact interface can
be adjusted for each
project as required
by the client**



Atrium Design



Summer Strategy
Upwards Displacement Ventilation



Winter Strategy
Winter Mixing Ventilation

Port Regis School, Dorset




Monkseaton School, Newcastle



Energy Savings

Fossil Fuels Energy Consumption kWh/m²/yr



* CIBSE Guide F Table 20.1 Fossil fuel use in secondary schools

** Total energy consumption of building





QAC, Birmingham



Port Regis School

Internal Climate



The daily average CO₂ never exceeds 1500ppm

BB101 Standards

120 hours for which $T_{\text{room}} > 28^{\circ}\text{C}$

$$(T_{\text{room}})_{\text{max}} = \mathbf{32^{\circ}\text{C}}$$

$$(T_{\text{room}} - T_{\text{external}})_{\text{max}} = \mathbf{5^{\circ}\text{C}}$$

Belvoir High School


0 hours for which $T_{\text{room}} > 28^{\circ}\text{C}$

$$(T_{\text{room}})_{\text{max}} = \mathbf{27.5^{\circ}\text{C}}$$

$$(T_{\text{room}} - T_{\text{external}})_{\text{max}} = \mathbf{2.3^{\circ}\text{C}}$$



Internal Comfort



Harston Primary School



Before



After

Internal Comfort



Priority School Building Programme

Making sense of the new Priority School Output Specification from the Education Funding Agency. How is the output specification different from previous guidelines, how do the standard school designs meet the output specification and how Breathing Buildings can help you model the ventilation system energy use in IES.



Summary

- Natural ventilation low energy
- Design parameters
 - Vent area
 - Head
 - Thermal mass
 - Wind
- Control strategy
 - Mixing Winter
 - Displacement Summer