



DO NOT SCALE

IF IN DOUBT, ASK!

REVISIONS			
REV.	DESCRIPTION	DATE	DRAWN
1	ADDED NOTE	22/02/2016	CC

- NOTES:
- NVHR FX 1A TYPE A SHOWN.
 - WALL SLEEVE CAN BE CUT ON-SITE TO SUIT CLEARANCE.
 - LOAD BEARING SUPPORTS MUST BE SIGNED OFF BY THE STRUCTURAL ENGINEER FOR THE PROJECT. WALL SLEEVE MUST NOT TAKE WEIGHT LOAD OF NVHR UNIT TO AVOID ANY CANTILEVERING.
 - SUSPENDED CEILINGS - 1 NO. 600X600 EGG CRATE GRILLES REQUIRED.
 - LEAVE PLASTIC PACKAGING ON DURING INSTALLATION.

MATERIAL:	N/A
FINISH	N/A
MASS WITHOUT PACKAGING	N/A
TOLERANCES EXCEPT WHERE OTHERWISE STATED	X ± 0.5MM X XX ± 0.05MM ANGLES ± 0.5°
SURFACE TEXTURE TO BE	1.6 UMRA OR BETTER

DE-BURR ALL SHARP EDGES AND HOLES. ITEM MUST BE FREE FROM SCRATCHES, DENTS AND OTHER BLEMISHES.

DIMENSIONS IN MILLIMETRES



15 STURTON STREET, CAMBRIDGE, CB1 2SN
T: 01223 450060 F: 01223 450061
www.breathingbuildings.com/products

TITLE:
**NVHR FX 1A TYPE A -
INSTALLATION WINDOW GA
(WITH SPIGOT)**

DRAWING NO:
1503_9003

REV	DRAWN	DATE	CHK'D	DATE
1	CC	22/02/2016		

SCALE 1:20 A3 SHEET 1 OF 1



BREATHING BUILDINGS CONTINUOUSLY WORK TO IMPROVE OUR PRODUCTS. TO ENSURE UP TO DATE DRAWINGS, PLEASE CONTACT BREATHING BUILDINGS.