



DO NOT SCALE

IF IN DOUBT, ASK!

| REVISIONS | | | |
|-----------|--------------------|------------|-------|
| REV. | DESCRIPTION | DATE | DRAWN |
| 1 | ADDED WEIGHT | 12/08/2016 | CC |
| 2 | DUCT SPLITTER NOTE | 21/11/2016 | CC |

- NOTES:
- NVHR 1A2 TYPE A SHOWN. WALL SLEEVE CAN BE CUT ON-SITE TO SUIT. STRUCTURAL OPENING OF 920X320MM IS REQUIRED.
 - WALL SLEEVE TO BE ATTACHED TO INTERNAL WALL. FIXING HOLES DRILLED AS REQUIRED ON-SITE.
 - INSULATED DUCT SLEEVE THROUGH WALL TO SUIT STRUCTURAL OPENING. TYP. PIR/PUR INSULATION BOARD. LOAD BEARING SUPPORTS MUST BE SIGNED OFF BY THE STRUCTURAL ENGINEER FOR THE PROJECT.
 - SUSPENDED CEILINGS - 1 NO. 600X600 EGG CRATE GRILLES REQUIRED.
 - DUCT SPLITTER NOT REQUIRED IF UNIT FITTED AGAINST REAR OF EXTERNAL WEATHER LOUVRE. NVHR FRONT FACE (DAMPER SIDE) MUST NOT EXTEND INTO FINISHED INTERIOR WALL MORE THAN 150MM.
 - LEAVE PLASTIC PACKAGING ON DURING INSTALLATION.

MATERIAL:

FINISH

MASS WITHOUT PACKAGING
NVHR 1A2 50KG

TOLERANCES EXCEPT WHERE OTHERWISE STATED

| | | |
|--------|---|--------|
| X | ± | 0.5MM |
| X XX | ± | 0.05MM |
| ANGLES | ± | 0.5° |

SURFACE TEXTURE TO BE 1.6 UMRA OR BETTER

DE-BURR ALL SHARP EDGES AND HOLES ITEM MUST BE FREE FROM SCRATCHES, DENTS AND OTHER BLEMISHES.

DIMENSIONS IN MILLIMETRES



15 STURTON STREET, CAMBRIDGE, CB1 2SN
T: 01223 450060 F: 01223 450061
www.breathingbuildings.com/products

TITLE:
NVHR 1A2 TYPE A (WITH GRILLE) - INSTALLATION WALL GA

DRAWING NO:
1603_9004

| REV | DRAWN | DATE | CHK'D | DATE |
|-----|-------|------------|-------|------|
| 2 | CC | 21/11/2016 | | |

SCALE 1:20 A3 SHEET 1 OF 1

BREATHING BUILDINGS CONTINUOUSLY WORK TO IMPROVE OUR PRODUCTS. TO ENSURE UP TO DATE DRAWINGS, PLEASE CONTACT BREATHING BUILDINGS.