



**DO NOT SCALE**

**IF IN DOUBT, ASK!**

REVISIONS			
REV.	DESCRIPTION	DATE	DRAWN
1	ADDED WEIGHT	12/08/2016	CC
2	DUCT SPLITTER NOTE	21/11/2016	CC

- NOTES:
- NVHR 1A2 TYPE A SHOWN. WALL SLEEVE CAN BE CUT ON-SITE TO SUIT CLEARANCE.
  - LOAD BEARING SUPPORTS MUST BE SIGNED OFF BY THE STRUCTURAL ENGINEER FOR THE PROJECT. WALL SLEEVE MUST NOT TAKE WEIGHT LOAD OF NVHR UNIT TO AVOID ANY CANTILEVERING. SUSPENDED CEILINGS - 1 NO. 600X600 EGG CRATE GRILLES REQUIRED.
  - LEAVE PLASTIC PACKAGING ON DURING INSTALLATION.

MATERIAL:	
FINISH	
MASS WITHOUT PACKAGING	NVHR 1A2 50KG
TOLERANCES EXCEPT WHERE OTHERWISE STATED	X ± 0.5MM X XX ± 0.05MM ANGLES ± 0.5°
SURFACE TEXTURE TO BE 1.6 UMRA OR BETTER	
DE-BURR ALL SHARP EDGES AND HOLES ITEM MUST BE FREE FROM SCRATCHES, DENTS AND OTHER BLEMISHES.	
DIMENSIONS IN MILLIMETRES	



15 STURTON STREET, CAMBRIDGE, CB1 2SN  
T: 01223 450060 F: 01223 450061  
www.breathingbuildings.com/products

TITLE:  
**NVHR 1A2 TYPE A (WITH GRILLE) - INSTALLATION WINDOW GA**

DRAWING NO:  
**1603\_9005**

REV	DRAWN	DATE	CHK'D	DATE
2	CC	21/11/2016		

SCALE 1:20 A3 SHEET 1 OF 1



BREATHING BUILDINGS CONTINUOUSLY WORK TO IMPROVE OUR PRODUCTS. TO ENSURE UP TO DATE DRAWINGS, PLEASE CONTACT BREATHING BUILDINGS.