



**DO NOT SCALE**

**IF IN DOUBT, ASK!**

REVISIONS			
REV.	DESCRIPTION	DATE	DRAWN
1	ADDED WEIGHT	12/08/2016	CC
2	DUCT SPLITTER NOTE	21/11/2016	CC

- NOTES:
- NVHR 1A2 TYPE A SHOWN. WALL SLEEVE CAN BE CUT ON-SITE TO SUIT. STRUCTURAL OPENING OF 920X320MM IS REQUIRED.
  - WALL SLEEVE TO BE ATTACHED TO INTERNAL WALL. FIXING HOLES DRILLED AS REQUIRED ON-SITE.
  - INSULATED DUCT SLEEVE THROUGH WALL TO SUIT STRUCTURAL OPENING. TYP. PIR/PUR INSULATION BOARD. LOAD BEARING SUPPORTS MUST BE SIGNED OFF BY THE STRUCTURAL ENGINEER FOR THE PROJECT.
  - SUSPENDED CEILINGS - 1 NO. 600X600 EGG CRATE GRILLES REQUIRED.
  - DUCT SPLITTER NOT REQUIRED IF UNIT FITTED AGAINST REAR OF EXTERNAL WEATHER LOUVRE. NVHR FRONT FACE (DAMPER SIDE) MUST NOT EXTEND INTO FINISHED INTERIOR WALL MORE THAN 150MM.
  - LEAVE PLASTIC PACKAGING ON DURING INSTALLATION.

MATERIAL:

FINISH

MASS WITHOUT PACKAGING  
NVHR 1A2 50KG

TOLERANCES EXCEPT WHERE OTHERWISE STATED

X	±	0.5MM
X XX	±	0.05MM
ANGLES	±	0.5°

SURFACE TEXTURE TO BE 1.6 UMRA OR BETTER

DE-BURR ALL SHARP EDGES AND HOLES ITEM MUST BE FREE FROM SCRATCHES, DENTS AND OTHER BLEMISHES.

DIMENSIONS IN MILLIMETRES

**Breathing Buildings**

UNIT 3A, THE SHADE, SOHAM CB7 5HF  
T: 01223 450060 F: 01223 450061  
www.breathingbuildings.com/products

TITLE:  
**NVHR 1A2 TYPE A (WITH GRILLE) - INSTALLATION WALL GA**

DRAWING NO:  
**1603\_9004**

REV	DRAWN	DATE	CHK'D	DATE
2	CC	21/11/2016		

SCALE 1:20 A3 SHEET 1 OF 1

BREATHING BUILDINGS CONTINUOUSLY WORK TO IMPROVE OUR PRODUCTS. TO ENSURE UP TO DATE DRAWINGS, PLEASE CONTACT BREATHING BUILDINGS.