



DO NOT SCALE

IF IN DOUBT, ASK!

REVISIONS			
REV.	DESCRIPTION	DATE	DRAWN
1	ADDED WEIGHT	12/08/2016	CC
2	DUCT SPLITTER NOTE	21/11/2016	CC

- NOTES:
- NVHR 1A2 TYPE A SHOWN. WALL SLEEVE CAN BE CUT ON-SITE TO SUIT CLEARANCE.
 - LOAD BEARING SUPPORTS MUST BE SIGNED OFF BY THE STRUCTURAL ENGINEER FOR THE PROJECT. WALL SLEEVE MUST NOT TAKE WEIGHT LOAD OF NVHR UNIT TO AVOID ANY CANTILEVERING. SUSPENDED CEILINGS - 1 NO. 600X600 EGG CRATE GRILLES REQUIRED.
 - LEAVE PLASTIC PACKAGING ON DURING INSTALLATION.

MATERIAL:	
FINISH	
MASS WITHOUT PACKAGING	NVHR 1A2 50KG
TOLERANCES EXCEPT WHERE OTHERWISE STATED	X ± 0.5MM X XX ± 0.05MM ANGLES ± 0.5°
SURFACE TEXTURE TO BE 1.6 UMRA OR BETTER	

DE-BURR ALL SHARP EDGES AND HOLES ITEM MUST BE FREE FROM SCRATCHES, DENTS AND OTHER BLEMISHES.

DIMENSIONS IN MILLIMETRES



UNIT 3A, THE SHADE, SOHAM CB7 5HF
T: 01223 450060 F: 01223 450061
www.breathingbuildings.com/products

TITLE:
NVHR 1A2 TYPE A (WITH GRILLE) - INSTALLATION WINDOW GA

DRAWING NO: 1603_9005				
REV	DRAWN	DATE	CHK'D	DATE
2	CC	21/11/2016		
SCALE 1:20		A3	SHEET 1 OF 1	



BREATHING BUILDINGS CONTINUOUSLY WORK TO IMPROVE OUR PRODUCTS. TO ENSURE UP TO DATE DRAWINGS, PLEASE CONTACT BREATHING BUILDINGS.