



DO NOT SCALE

IF IN DOUBT, ASK!

REVISIONS			
REV.	DESCRIPTION	DATE	DRAWN
1	ADDED WEIGHT	12/08/2016	CC
2	REVISED BRACKET POSITION	05/09/2016	CC

- NOTES:
- NVHR+ TYPE B SHOWN.
 - WALL FRAME CAN BE CUT ON-SITE TO SUIT. STRUCTURAL OPENING OF 920X320MM IS REQUIRED.
 - WALL FRAME TO BE ATTACHED TO INTERNAL WALL. FIXING HOLES DRILLED AS REQUIRED ON-SITE.
 - INSULATED DUCT SLEEVE THROUGH WALL TO SUIT STRUCTURAL OPENING, TYP. PIR/PUR INSULATION BOARD. LOAD BEARING SUPPORTS MUST BE SIGNED OFF BY THE STRUCTURAL ENGINEER FOR THE PROJECT.
 - SUSPENDED CEILINGS - 1 NO. 600X600 EGG CRATE GRILLES REQUIRED.
 - 10X320X500 FOAMALUX SPLITTER NOT REQUIRED IF UNIT FITTED AGAINST REAR OF EXTERNAL WEATHER LOUVRE. NVHR FRONT FACE (DAMPER SIDE) MUST NOT EXTEND INTO FINISHED INTERIOR WALL MORE THAN 150MM.
 - LEAVE PLASTIC PACKAGING ON DURING INSTALLATION.

MATERIAL:

FINISH

MASS WITHOUT PACKAGING
NVHR+ 80KG

TOLERANCES EXCEPT WHERE OTHERWISE STATED

X	±	0.5MM
X XX	±	0.05MM
ANGLES	±	0.5°

SURFACE TEXTURE TO BE 1.6 UMRA OR BETTER

DE-BURR ALL SHARP EDGES AND HOLES ITEM MUST BE FREE FROM SCRATCHES, DENTS AND OTHER BLEMISHES.

DIMENSIONS IN MILLIMETRES



UNIT 3A, THE SHADE, SOHAM CB7 5HF
T: 01223 450060 F: 01223 450061
www.breathingbuildings.com/products

TITLE:
NVHR+ INSTALLATION WALL GA

DRAWING NO:
1604_9001

REV	DRAWN	DATE	CHK'D	DATE
2	CC	05/09/2016		

SCALE 1:20 A3 SHEET 1 OF 1